NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: NI016583.02
DATE: 04/07/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Hy-Lite
CODE: 3155-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Hy-Lite Specialty Products **3000 E. Johnson Avenue** **Pensacola, Florida 32514**	**Series "VF1500-8"** **Vinyl Fixed Window** Configuration: O Glazing: 8" x 8" x 1.5" Acrylic Block - Qty. 81 Frame: W-1880mm (74") H-1880mm (74") DLO: W-1797mm (70.75") H-1797mm (70.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11	**Class CW-PG40 1880 x 1880 (74 x 74)-FW** **Design Pressure: 1920 Pa (40 psf)** **Negative Design Pressure: 2400 Pa (50 psf)** **Water Penetration Resistance Test Pressure: 720 Pa (15.00 psf)**

Product Tested By: Certified Testing Laboratories
Report No: CTLA 3015W-2
Expiration Date: **April 30, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com