

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016692
DATE: 06/18/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Alucorp
CODE: 2432-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Alucorp S.A. De C.V. Calle 2 Tab 17439 Int. C X21 Y25 Chichi Suarez Merida, Yucatan, Mexico 97305	Series "76 MD" Vinyl Double Tilt & Turn Window Configuration: X/X Glazing: IG- 1/4" Tempered Glass/3/16" Heat Strengthened Glass/0.090" Kuraray Sentry Glass Interlayer/3/16" Heat Strengthened Glass Frame: W-2602mm(102.44") H-1613mm(63.5") Sash: W-1251mm(49.25") H-1524mm(60") DLO: W-1094mm(43.06") H-1369mm(53.9")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±3112 Pa (65 psf) Water Penetration Resistance Test Pressure: 575 Pa (12.0 psf) Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4116-07
Expiration Date: June 30, 2029

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

nami@namiinc.com

NOPC-03/30/2023