

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016695
DATE: 06/18/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Alucorp
CODE: 2432-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Alucorp S.A. De C.V. Calle 2 Tab 17439 Int. C X21 Y25 Chichi Suarez Merida, Yucatan, Mexico 97305	Series "76 MD Vinyl In-Swing Balcony Door" Vinyl Balcony Door Configuration: X Glazing: IG- 1/4" Tempered Glass/3/16" Heat Strengthened Glass/0.090" Kuraray SentryGlas Interlayer/3/16" Heat Strengthened Glass Frame: W-1168mm(46") H-2108mm(83") Panel: W-1073mm(42.25") H-2026mm(79.75") DLO: W-914mm(36") H-1867mm(73.5")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 ASTM E1886-05/E1996-05/09 TAS 201/202/203-94	Class LC-PG65 1168 x 2108 (46 x 83)-DASHD Design Pressure: ±3120 Pa (65 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.0 psf) Wind Zone 4 - Missile Level D Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-4116-10/NCTL-210-4116-09
Expiration Date: June 30, 2029

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com

NOPC-03/30/2023