

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016316
DATE: 08/26/2024
CERTIFICATION PROGRAM: Structural
COMPANY: Quaker
CODE: 031-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Quaker Window Products 504 Highway 63 South Freeburg, MO 65035	Series "H4503 Fixed (Annealed)" Aluminum Fixed Window Configuration: O Glazing: Insulating Glass - Annealed Frame: W-2515mm(99") H-1524mm(60") DLO: W-2454mm(96.63") H-1464mm(57.63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 AAMA/WDMA/CSA 101/I.S.2/A440-17 CSA A440S1-19 CSA A440S1-17	Class AW-PG50 2515 x 1524 (99 x 60)-FW Design Pressure: ± 2400 Pa (± 50 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.03 psf) Canadian Air Infiltration/Exfiltration Level: Fixed

Product Tested By: Quast Consulting & Testing, Inc
Report No: QCT24-7320.01/QCT24-732002
Expiration Date: July 31, 2028

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023