NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI016317.01**
DATE:	**08/26/2024**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Quaker**
CODE:	**031-1**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Quaker Window Products **504 Highway 63 South** **Freeburg, MO 65035**	**Series "H4503"** **Aluminum Awning Window** **(Roto)** Configuration: X Glazing: Insulating Glass - Annealed Frame: W-1524mm(60") H-914mm(36") Sash: W-1489mm(58.63") H-880mm(34.63") DLO: W-1397mm(55") H-787mm(31")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 **AAMA/WDMA/CSA 101/I.S.2/A440-17** **CSA A440S1-19** **CSA A440S1-17**	**Class CW-PG85 1524 x 914 (60 x 36)-AP** **Design Pressure: ±4080 Pa (±85 psf)** **Water Penetration Resistance Test Pressure: 720 Pa (15.03 psf)** **Canadian Air Infiltration/Exfiltration Level: A2**

Product Tested By: Quast Consulting & Testing, Inc
Report No: QCT24-7320.04
Expiration Date: **July 31, 2028**

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com