Hallmark® Certificate of Conformance and License (CCL)

WINDOW & DOOR MANUFACTURERS ASSOCIATION WDMA

AMS, INC. Administrative Management Systems, Inc.

Sierra Pacific Windows
11605 Reading Road
PO Box 8489
Red Bluff, CA 96080

Mfr ID: 429
For more Information visit www.amscert.com
Website: www.sierrapacificwindows.com
TEL: 530-527-9620

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
429-H-566.04	SP Clad Direct Set-Awning Mull 96x108 (96x72 Direct Set/48x36-2Awning)	101/I.S.2/A440-22	Class CW-PG35; Size Tested 96 x 108 Type-AP; DP +35/-35 psf; Water Test Press 260Pa (5.43psf); Can. Air Infil/Exfil. Level=A3	96	108	s3082.01-901-47-R1	4/15/2025	5/29/2025	9/24/2034
429-H-566.05	SP Clad Direct Set-Awning Mull 96x108 (96x72 Direct Set/48x36-2Awning)	101/I.S.2/A440-17	Class CW-PG35; Size Tested 96 x 108 Type-AP; DP +35/-35 psf; Water Test Press 260Pa (5.43psf); Can. Air Infil/Exfil. Level=A3	96	108	s3082.01-901-47-R1	4/15/2025	5/29/2025	9/24/2034
429-H-566.07	SP Clad Direct Set-Awning 2438mmx2743mm Mull(2438x1828 Direct Set/1219x914-2Awning)	CSA A440 S1-17	Class CW-PG35; Size Tested 2438 x 2743 Type-AP; DP +35/-35 psf; Water Test Press 260Pa (5.43psf); Can. Air Infil/Exfil. Level=A3	2438	2743	s3082.01-901-47	4/15/2025	5/29/2025	9/24/2034

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By: *John McFee, VP of Certification Programs, WDMA Hallmark*

By: *Lucas L. Wenzel, Authorized Representative, AMS*

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com