

Hallmark® Certificate of Conformance and License (CCL)




AMS, INC.
Administrative Management
Systems, Inc.


Sierra Pacific Windows
11605 Reading Road
PO Box 8489
Red Bluff, CA 96080

Mfr ID: 429
For more Information visit www.amscert.com
Website: www.sierrapacificwindows.com
TEL: 530-527-9620

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
429-H-567.12	SP Aluminum Clad Direct Set Combo Unit 96 -1/4x120" (48x60-2/48x60-2)	101/I.S.2/A440-22	Class LC-PG50; Size Tested 96-1/4in x 120in Type-FW; DP +2400/-2400 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=Fixed	96-1/4in	120in	s5169.01-901-47-R1	6/4/2025	6/20/2025	11/19/2034
429-H-567.13	SP Aluminum Clad Direct Set Combo Unit 96 -1/4x120" (48x60-2/48x60-2)	101/I.S.2/A440-17	Class LC-PG50; Size Tested 96-1/4in x 120in Type-FW; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=Fixed	96-1/4in	120in	s5169.01-901-47-R1	6/4/2025	6/20/2025	11/19/2034
429-H-567.14	SP Aluminum Clad Direct Set Combo Unit 96 -1/4x120" (48x60-2/48x60-2)	101/I.S.2/A440-11	Class LC-PG50; Size Tested 96-1/4in x 120in Type-FW; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=Fixed	96-1/4in	120in	s5169.01-901-47-R1	6/4/2025	6/20/2025	11/19/2034
429-H-567.15	SP Aluminum Clad Direct Set Combo Unit 2445x3048mm (1219x1524mm-2/1219x1524mm-2)	CSA A440 S1-17	Class LC-PG50; Size Tested 2445mm x 3048mm Type-FW; DP +2400/-2400 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=Fixed	2445mm	3048mm	s5169.01-901-47-R1	6/4/2025	6/20/2025	11/19/2034

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  **John McFee, VP of Certification Programs, WDMA Hallmark**

By:  **Lucas L. Wenzel, Authorized Representative, AMS**

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com