

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO:	NI016720.01
DATE:	07/22/2025
CERTIFICATION PROGRAM:	Structural
COMPANY:	Sunset Windows
CODE:	2348-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Sunset Windows and Doors, LLC 910 Warehouse Road, Unit 110104 Orlando, FL 32803	Series "5400 OXO" Vinyl Sliding Glass Door (w/o Sill Riser) Configuration: OXO Glazing: Insulating Glass (Tempered) Frame: W-3734mm(147") H-2438mm(96") Panel: W-1235mm(48.63") H-2370mm(93.31") DLO: W-1054mm(41.50") H-2191mm(86.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22	Class LC-PG40 3734 x 2438 (147 x 96)-SD Design Pressure: 1920 Pa (40 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Level: 290 Pa (6.06 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Intertek, PLC
Report No: Q9480.02-901-44/Q9479.02-901-44
Expiration Date: **June 30, 2028**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com

NOPC-03/30/2023