NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI016720.04**
DATE:	**07/23/2025**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Sunset Windows**
CODE:	**2348-1**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Sunset Windows and Doors, LLC **910 Warehouse Road, Unit 110104** **Orlando, FL 32803**	**Series "5400 OXXO"** **Vinyl Sliding Glass Door** **(w/Sill Riser)** Configuration: OXXO Glazing: Insulating Glass (Tempered) Frame: W-4877mm(192") H-2438mm(96") Panel: W-1238mm(48.75") H-2372mm(93.38") DLO: W-1054mm(41.50") H-2191mm(86.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22	**Class LC-PG50 4877 x 2438 (192 x 96)-SD** **Design Pressure: ±2400 Pa (±50 psf)** **Water Penetration Resistance Level: 360 Pa (7.52 psf)** **Canadian Air Infiltration/Exfiltration Level: A3**

Product Tested By: Intertek, PLC
Report No: Q9481.02-901-44
Expiration Date: **June 30, 2028**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com