

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016777.03
DATE: 08/04/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Quaker
CODE: 031-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Quaker Window Products 504 Highway 63 South Freeburg, MO 65035	Series "C200 & W200 Low Sill" Aluminum Sliding Glass Door Configuration: XO Glazing: Insulating Glass (Tempered) Frame: W-2210mm(87") H-2438mm(96") Panel: W-1118mm(44") H-2369mm(93.25") DLO: W-933mm(36.75") H-2172mm(85.50")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22	Class R-PG25 2210 x 2438 (87 x 96)-SD Class LC-PG25 2210 x 2438 (87 x 96)-SD Design Pressure: 1200 Pa (25 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 180 Pa (3.76 psf) Canadian Air Infiltration/Exfiltration Level: A2

Product Tested By: Intertek, PLC
Report No: S2121.04-801-47
Expiration Date: **January 31, 2029**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023