NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI016783.01**
DATE:	**08/13/2025**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Quaker**
CODE:	**031-1**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Quaker Window Products **504 Highway 63 South** **Freeburg, MO 65035**	**Series "C200 & W200"** **Aluminum French Outswing** **Side Hinged Door** Configuration: XX Glazing: Insulating Glass (Tempered) Frame: W-1829mm(72") H-2438mm(96") Panel: W-879mm(34.63") H-2389mm(93.38") DLO: W-703mm(27.69") H-2194mm(86.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22	**Class LC-PG50 1829 x 2438 (72 x 96)-SHD** **Class R-PG50 1829 x 2438 (72 x 96)-SHD** **Design Pressure: ±2400 Pa (±50 psf)** **Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)** **Canadian Infiltration/Exfiltration Level: A2**

Product Tested By: Intertek, LLC
Report No: S2558.01-801-44
Expiration Date: **June 30, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com