

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016653.02-R1
DATE: 05/20/2025
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 08/19/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	“Builders Fiberglass Swinging Door” Fiberglass Inswing Direct Glazed Side Hinged Door Configuration: XX Glazing: Insulating Glass (Tempered) Frame: W-1880mm(74") H-2076mm(81.75") Panel: W-908mm(35.75") H-2013mm(79.25") DLO: W-533mm(21") H-1600mm(63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 AAMA/WDMA/CSA 101/I.S.2/A440-17 CSA A440S1-17	Class R-PG50 1880 x 2076 (74 x 82)-LW SHD Design Pressure: 2400 Pa (50 psf) Positive Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2640 Pa (55 psf) Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf) Canadian Air infiltration/Exfiltration Level: A2

Product Tested By: Molimo, LLC
Report No: 30247.01-201-12/30381.01-201-12
Expiration Date: **February 28, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023