NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI016078.08-R1**
DATE:	**06/10/2025**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**JELD-WEN**
CODE:	**1822-1**
REVISION DATE:	**08/19/2026**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN **3737 Lakeport Boulevard** **Klamath Falls, OR 97601**	**"Builders Fiberglass Swinging Door"** **Fiberglass Outswing Glazed** **Side Hinged Door** Configuration: XX Glazing: IG-Ext. 1/8" Annealed Glass/0.090" PVB Interlayer by Kuraray/1/8" Annealed Glass/Int. 1/8" Tempered Glass Frame: W-1873mm(73.75") H-2045mm(80.50") Panel: W-908mm(35.75") H-2013mm(79.25") DLO: W-524mm(20.63") H-1591mm(62.63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 **AAMA/WDMA/CSA 101/I.S.2/A440-17** **CSA A440S1-17** **ASTM E1886-19** **ASTM E1996-20**	**Class R-PG50 1873 x 2045 (74 x 81)-LW SHD** **Design Pressure: 2400 Pa (50 psf)** **Positive Design Pressure: 2400 Pa (50 psf)** **Negative Design Pressure: 2640 Pa (55 psf)** **Water Penetration Resistance Test Pressure: 0 Pa (0.00 psf)** **Canadian Air infiltration/Exfiltration Level: A2** **Missile Level D - Wind Zone 3**

Product Tested By: Molimo, LLC
Report No: 30440.01-201-12
Expiration Date: **April 30, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com