Hallmark® Certificate of Conformance and License (CCL)

AMS, INC.
Administrative Management Systems, Inc.

Marvin
PO Box 100
401 State Ave N.
Warroad, MN 56763

Mfr ID: 407
For more Information visit www.amscert.com
Website: www.marvin.com
TEL: 218-386-1430

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	RptDate	CertDate	ExpDate
407-H-1179.01	Vivid MRF Mull 2W1H	AAMA 450-20	Class LC-PG40; Size Tested 72.5" Trib Width x 96" Span Type-MA; Water Test Press 360Pa (7.52psf)	72.5" Trib Width	96" Span	30207.03-301-12	10/16/2025	8/7/2025	10/14/2035
407-H-1179.08	Vivid MRF Mull 2W1H	101/I.S.2/A440-17	Class LC-PG25; Size Tested 72.5" Trib Width x 96" Span Type-MA; Water Test Press 180Pa (3.76psf); Can. Air Infil/Exfil. Level=A3	72.5" Trib Width	96" Span	30207.03-301-12	10/16/2025	10/20/2025	10/14/2035

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By: John McFee *John McFee, VP of Certification Programs, WDMA Hallmark*

By: Lucas L. Wenzel *Lucas L. Wenzel, Authorized Representative, AMS*

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com