

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016820
DATE: 10/06/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Intus
CODE: 1817-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Intus Windows, LLC 2720 Prosperity Avenue, 400-1 Fairfax, VA 22031	Series "NextGen" uPVC Sliding Glass Door Configuration: XO Glazing: IG - 1/4" Tempered Glass/5/32" Annealed Glass/0.090" Trosifol XT PVB Interlayer/5/32" Annealed Glass Frame: W-3099mm(122") H-2438mm(96") Panel: W-1527mm(60.13") H-2321mm(91.38") DLO: W-1346mm(53") H-2134mm(84")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 ASTM E1886-19 ASTM E1996-23 TAS 201/202/203-94	Class AW-PG70 3100 x 2438 (122 x 96)-SD Design Pressure: ± 3360 Pa (± 70 psf) Water Penetration Resistance Test Pressure: 720 Pa (15.04 psf) Wind Zone 4 - Missile Level A Small Missile Impact Rated

Product Tested By: Molimo, LLC
Report No: 29852.01-106-11/29854.01-106-13/29854.02-106-13
Expiration Date: **December 31, 2028**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Molimo".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023