

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016804
DATE: 08/28/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Croft
CODE: 1887-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Croft, LLC 1800 North Clark Avenue Magnolia, MS 39652	Series "11FPW" Vinyl Fixed Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1829mm(72") H-1829mm(72") DLO: W-1727mm(68") H-1727mm(68")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/1.S.2/A440-17	Class R-PG50 1829 x 1829 (72 x 72)-FW Design Pressure: ± 2400 Pa (± 50 psf) Water Penetration Resistance Test: 580 Pa (12.11 psf)

Product Tested By: PRI Construction Materials Technologies, LLC
Report No: 2189T0065
Expiration Date: July 31, 2029

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023