

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016783.02
DATE: 10/21/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Quaker
CODE: 031-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Quaker Window Products 504 Highway 63 South Freeburg, MO 65035	Series "C200 & W200" Fixed Aluminum French Inswing Side Hinged Door Configuration: OO Glazing: Insulating Glass (Tempered) Frame: W-1829mm(72") H-2438mm(96") Panel: W-879mm(34.63") H-2389mm(94.06") DLO: W-703mm(27.69") H-2194mm(86.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22	Class LC-PG50 1829 x 2438 (72 x 96)-LW SHD X Class R-PG50 1829 x 2438 (72 x 96)-LW SHD X Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 180 Pa (3.76 psf) Canadian Infiltration/Exfiltration Level: A2

Product Tested By: Intertek, LLC
Report No: S8421.05-801-47/W-2174
Expiration Date: July 31, 2029

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023