

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016832.05
DATE: 10/22/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Quaker
CODE: 031-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Quaker Window Products 504 Highway 63 South Freeburg, MO 65035	Series "C200 DS & W200 DS" Cityline Direct Set Timberline Direct Set Aluminum Fixed Door Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-1270mm(50") H-2438mm(96") DLO: W-1172mm(46.13") H-2338mm(92.06")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22	Class LC-PG50 1270 x 2438 (50 x 96)-FD Design Pressure: ± 2400 Pa (± 50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Infiltration/Exfiltration Level: Fixed

Product Tested By: Quast Consulting & Testing Inc.
Report No: QCT25-7572.07
Expiration Date: April 30, 2029

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD", is written over the signature line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023