NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI016832**
DATE:	**10/22/2025**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Quaker**
CODE:	**031-1**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Quaker Window Products **504 Highway 63 South** **Freeburg, MO 65035**	**Series "C200I & W200I"** **Cityline Inswing Narrow - Sidelite** **Timberline Inswing Narrow - Sidelite** **Aluminum Fixed Door** Configuration: O Glazing: Insulating Glass (Tempered) Frame: W-1270mm(50") H-2438mm(96") DLO: W-1029mm(40.50") H-2184mm(86")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22	**Class LC-PG50 1270 x 2438 (50 x 96)-FD** **Design Pressure: ±2400 Pa (±50 psf)** **Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)** **Canadian Infiltration/Exfiltration Level: Fixed**

Product Tested By: Quast Consulting & Testing Inc.
Report No: QCT25-7572.02
Expiration Date: **April 30, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com