

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016827.01
DATE: 10/20/2025
CERTIFICATION PROGRAM: Structural
COMPANY: Croft
CODE: 1887-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Croft, LLC 1800 North Clark Avenue Magnolia, MS 39652	Series "10" Vinyl Single Hung Window Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-921mm(36.25") H-1835mm(72.25") Sash: W-841mm(33.13") H-902mm(35.50") DLO: W-770mm(30.31") H-827mm(32.56")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/1.S.2/A440-17 AAMA/WDMA/CSA 101/1.S.2/A440-11	Class R-PG50 921 x 1835* (36 x 72*)-H Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Molimo, LLC
Report No: 31775.01-109-11
Expiration Date: September 30, 2029

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023