


NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011086-R2
DATE: 05/02/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Sun-Tek
CODE: 225-1
REVISION DATE: 12/11/2025

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namincertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Sun-Tek Manufacturing, Inc. 10303 General Drive Orlando, FL 32824	Series "CMA-D" Polycarbonate Curb Mounted Aluminum Fixed Skylight Dade Configuration: O Glazing: Polycarbonate Outer Dome Thickness-0.118"/Inner Liner Thickness-0.080" Frame: W-1286mm(50.63") H-2379mm(93.63") DLO: W-1083mm(46.5") H-2175mm(89.5")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: +60/-60 psf Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL 210-3716-2
Expiration Date: November 30, 2027

Administrator's Signature: _____

NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com

NOPC-03/30/2023