NOTICE OF PRODUCT CERTIFICATION

Company: **Pella Corporation**
102 Main Street
Pella, IA 50219

Certification No.: **NI016872.01**
Certification Date: **01/07/2026**
Expiration Date: **01/31/2030**

Product: **Fiberglass Impact Rated Glazed Inswing or Outswing Door w/ and w/o Impact Rated Sidelites**
Endura Trilennium or Panolock Multipoint Hardware
(w/Wood Frame or Worldwide Composite Frame[4] unless noted)

Specification: TAS 201/202/203-94/ASTM E330-02/14/M-14

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Structural Design Pressure	Water Test Pressure	Missile Impact Rated	Test Report Number Drawing Number & Comments
X Single	I/S	Glazed	3'0" x 8'0"	+40/-45	0 psf	Yes	NCTL-210-3389-1/ATLNC 1203.01-14/ATLNC 1012.01-16 Maximum Panel Size: 3'0" x 8'0" W-1807/W-1885/W-2106/W-2107
X Single	O/S	Glazed	3'0" x 8'0"	+45/-45	3.75 psf [1]/6.0 psf [2] 8.25 psf [3]/9.0 psf [5]	Yes	NCTL-210-3389-1/ATLNC 1203.01-14/ATLNC 1012.01-16 Maximum Panel Size: 3'0" x 8'0" W-1807/W-1835/W-1885/W-2106/W-2107
XX Double	I/S	Glazed	6'0" x 8'0"	+40/-45	0 psf	Yes	NCTL-210-3389-1/ATLNC 1203.01-14/ATLNC 1012.01-16 Maximum Panel Size: 3'0" x 8'0" W-1807/W-1885/W-2106/W-2107
XX Double	O/S	Glazed	6'0" x 8'0"	+45/-45	3.75 psf [1]/6.0 psf [2] 8.25 psf [3]/8.25 psf [5]	Yes	NCTL-210-3389-1/ATLNC 1203.01-14/ATLNC 1012.01-16 Maximum Panel Size: 3'0" x 8'0" W-1807/W-1835/W-1885/W-2106/W-2107
XO/OX Single w/Sidelite	I/S	Glazed Door Glazed Sidelite	6'0" x 8'0"	+40/-45	0 psf	Door-Yes Sidelite-Yes	NCTL-210-3389-1/ATLNC 1203.01-14/ATLNC 1012.01-16 Maximum Panel Size: 3'0" x 8'0"/Sidelite: 3'0" x 8'0" W-1807/W-1885/W-2106/W-2107
XO/OX Single w/Sidelite	O/S	Glazed Door Glazed Sidelite	6'0" x 8'0"	+45/-45	3.75 psf [1]/6.0 psf [2] 8.25 psf [3]/9.0 psf [5]	Door-Yes Sidelite-Yes	NCTL-210-3389-1/ATLNC 1203.01-14/ATLNC 1012.01-16 Maximum Panel Size: 3'0" x 8'0" /Sidelite: 3'0" x 8'0" W-1807/W-1835/W-1885/W-2106/W-2107
OXO Single w/Sidelites	I/S	Glazed Door Glazed Sidelites	9'0" x 8'0"	+40/-45	0 psf	Door-Yes Sidelite-Yes	NCTL-210-3389-1/ATLNC 1203.01-14/ATLNC 1012.01-16 Maximum Panel Size: 3'0" x 8'0" /Sidelite: 3'0" x 8'0" W-1807/W-1885/W-2106/W-2107
OXO Single w/Sidelites	O/S	Glazed Door Glazed Sidelites	9'0" x 8'0"	+45/-45	3.75 psf [1]/6.0 psf [2] 8.25 psf [3]/9.0 psf [5]	Door-Yes Sidelite-Yes	NCTL-210-3389-1/ATLNC 1203.01-14/ATLNC 1012.01-16 Maximum Panel Size: 3'0" x 8'0" /Sidelite: 3'0" x 8'0" W-1807/W-1835/W-1885/W-2106/W-2107
OXXO Double w/Sidelites	I/S	Glazed Doors Glazed Sidelites	12'4" x 8'0"	+40/-45	0 psf	Door-Yes Sidelite-Yes	NCTL-210-3389-1/ATLNC 1203.01-14/ATLNC 1012.01-16 Maximum Panel Size: 3'0" x 8'0" /Sidelite: 3'0" x 8'0" W-1807/W-1885/W-2106/W-2107
OXXO Double w/Sidelites	O/S	Glazed Doors Glazed Sidelites	12'4" x 8'0"	+45/-45	3.75 psf [1]/6.0 psf [2] 8.25 psf [3]/8.25 psf [5]	Door-Yes Sidelite-Yes	NCTL-210-3389-1/ATLNC 1203.01-14/ATLNC 1012.01-16 Maximum Panel Size: 3'0" x 8'0" /Sidelite: 3'0" x 8'0" W-1807/W-1835/W-1885/W-2106/W-2107

1-Denotes Bumper Outswing Threshold Design 2-Denotes Z-Series Outswing Threshold Design 3-Denotes High Dam Outswing Threshold Design 4-W-1815 5-Denotes Worldwide Pro T4 Threshold

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072
Tel: (804) 684-5124/nami@namiinc.com

NAMI AUTHORIZED SIGNATURE: _____