

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016873.01
DATE: 01/07/2026
CERTIFICATION PROGRAM: Structural
COMPANY: Pella
CODE: 1735-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Pella Corporation 102 Main Street Pella, IA 50219	Flush Glazed Fiberglass Outswing Fiberglass Side-Hinged Door Assembly w/Sidelites Configuration: OXXO Glazing: IG-5/32" Tempered Glass/1/8" Heat Strengthened Glass/0.090" Kuraray Trosifol PVB Interlayer/1/8" Heat Strengthened Glass Frame: W-3785mm(149") H-2048mm(80.63") Panel: W-908mm(35.75") H-2013mm(79.25") DLO: W-635mm(25") H-1600mm(63")

SPECIFICATION	PRODUCT RATING
ASTM E330-14 ASTM E283-04 ASTM E331-00 TAS 202-94 (Limited Water) TAS 201/203-94	Positive Design Pressure: (60 psf) Negative Design Pressure:(55 psf) Water Penetration Resistance Test Pressure: 5.25 psf¹ Water Penetration Resistance Test Pressure: 6.0 psf² Water Penetration Resistance Test Pressure: 7.05 psf³ Water Penetration Resistance Test Pressure: 7.5 psf⁴ Large Missile Impact Rated

Note: 1 - Bumper Threshold / 2 - Z-Series Threshold / 3 - High Dam Threshold/4- HP Outswing Threshold for Single Door Only

Product Tested By: **American Test Lab, Inc. (ATLNC)**
Report No: **ATLNC 0604.01-24/W-1842/W-1878/W-2107/W-2130/W-1860**
Expiration Date: **January 31, 2030**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com

NOPC-03/30/2023