NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI016873.05**
DATE:	**01/07/2026**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Pella**
CODE:	**1735-1**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Pella Corporation **102 Main Street** **Pella, IA 50219**	**Flush Glazed Fiberglass Outswing** **Fiberglass Side-Hinged Door Assembly** Configuration: XX Glazing: IG-1/8" Tempered Glass/1/8" Heat Strengthened Glass/0.090" PVB Interlayer/1/8" Heat Strengthened Glass Frame: W-1880mm(74") H-2454mm(96") Panel: W-908mm(35.75") H-2419mm(95.25") DLO: W-635mm(25") H-2007mm(79")

SPECIFICATION	PRODUCT RATING
ASTM E330-14 **ASTM E283-04** **ASTM E331-00** **TAS 202-94** **(Limited Water)** **TAS 201/203-94**	**Positive Design Pressure: ±45 psf** **Water Penetration Resistance Test Pressure: 0 psf** **(with Bumper Threshold: 5.25 psf)** **(with Z-Series Threshold: 6.00 psf)** **(with High Dam Threshold: 7.05 psf)** **Large Missile Impact Rated**

Product Tested By: American Test Lab, Inc. (ATLNC)
Report No: ATLNC 0310.01-25/W-1842/W-1878/W-1972/W-2107/W-2160
Expiration Date: **January 31, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com