

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016873.07
DATE: 01/07/2026
CERTIFICATION PROGRAM: Structural
COMPANY: Pella
CODE: 1735-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Pella Corporation 102 Main Street Pella, IA 50219	Flush Glazed Fiberglass Outswing Fiberglass Side-Hinged Door Assembly Configuration: OXO Glazing: IG-1/8" Tempered Glass/1/8" Heat Strengthened Glass/0.090" PVB Interlayer/1/8" Heat Strengthened Glass Frame: W-2858mm(112.5") H-2454mm(96.63") Panel: W-908mm(35.75") H-2419mm(95.25") DLO: W-635mm(25") H-2007mm(79")

SPECIFICATION	PRODUCT RATING
ASTM E330-14 ASTM E283-04 ASTM E331-00 TAS 202-94 (Limited Water) TAS 201/203-94	Positive Design Pressure: ±50 psf Water Penetration Resistance Test Pressure: 0 psf (with Bumper Threshold: 5.25 psf) (with Z-Series Threshold: 6.00 psf) (with High Dam Threshold: 7.05 psf) Large Missile Impact Rated

Product Tested By: American Test Lab, Inc. (ATLNC)
Report No: ATLNC 0304.01-25/W-1842/W-1878/W-1972/W-2107/W-2160
Expiration Date: January 31, 2030

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com

NOPC-03/30/2023