


NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016891
DATE: 01/27/2026
CERTIFICATION PROGRAM: Structural
COMPANY: Phos
CODE: 2118-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Phos Window, LLC 1201 Echols Drive West Fort Payne, AL 35968	Series "830-PD/800-PD Vinyl Sliding Door (New Construction & Replacement) Configuration: XO Glazing: IG:Ext.-1/8" Tempered Glass/Int.-1/8" Annealed Glass/0.090" Saflex PVB Interlayer/1/8" Annealed Glass Frame: W-1829mm(72") H-2032mm(80") Panel: W-930mm(36.63") H-1954mm(76.94") DLO: W-803mm(31.63") H-1826mm(71.88")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 AAMA/WDMA/CSA 101/I.S.2/A440-17 ASTM E1886-19 ASTM E1996-20	Class R-PG50 1829 x 2032 (72 x 80)-SD Design Pressure: ± 2400 Pa (± 50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Missile Level D - Wind Zone 3

Product Tested By: Molimo, LLC
Report No: 31811.01-109-11/31812.01-109-11
Expiration Date: December 31, 2029

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023