

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016890-R1
DATE: 01/27/2026
CERTIFICATION PROGRAM: Structural
COMPANY: Lippert
CODE: 206-1
REVISION DATE: 02/11/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Lippert Components, Inc. 5001 North Graham Street Charlotte, NC 28269	Series "3300 Rep./3400 NC/3405 NC no J" Vinyl Single Hung Window (New Construction & Replacement) Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1118mm(44") H-1829mm(72") Sash: W-1060mm(41.75") H-895mm(35.25") DLO: W-1005mm(39.56") H-826mm(32.50")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG50 1118 x 1829 (44 x 72)-H Design Pressure: ± 2400 Pa (± 50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: A3

Product Tested By: Molimo, LLC
Report No: 31981.02-109-11
Expiration Date: November 30, 2029

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Molimo".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/31/2023