

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016951
DATE: 04/16/2026
CERTIFICATION PROGRAM: Structural
COMPANY: Regency
CODE: 750-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Regency Plus, Inc. 2000 Locust Gap Highway Mount Carmel, PA 17851	Series "5210" Vinyl Twin Casement Window Configuration: XX Glazing: IG-Ext. 3/32" Annealed Glass/0.090" Kuraray Trosifol PVB Interlayer/3/32" Annealed Glass/Int. 3/16" Tempered Glass Frame: W-1873mm(73.75") H-1600mm(63") Vent: W-908mm(35.75") H-1562mm(61.50") DLO: W-772mm(30.38") H-1432mm(56.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 AAMA/WDMA/CSA 101/I.S.2/A440-17 ASTM E1886-19 ASTM E1996-20 TAS 201/202/203-94	Class LC-PG55 1873 x 1600 (74 x 63)-C Design Pressure: ± 2640 Pa (± 55 psf) Water Penetration Resistance Test Pressure: 400 Pa (8.36 psf) Missile Level D - Wind Zone 4 Large Missile Impact Rated

Product Tested By: Molimo, LLC
Report No: 31511.01-106-11/31511.02-106-11/31511.03-106-13
Expiration Date: February 28, 2030

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023