



Impact Performance Certification Authorization Report

ES Windows LLC

10653 NE Quaybridge Ct.
Miami, FL 33138, USA

Certification ID:	875-191
Company Code:	875
Certification Date:	5/7/2026
Revision No:	0
Revision Date:	5/7/2026
Expiration Date:	4/29/2030

Product Rating Information:

Model:	ES-V200 3-lite Horizontal Slider (XOX-Equal)		
Operator Type:	HS		
Configuration:	All/EM/H/S, GS - 5/16" HS Lami IG		
Referenced Standard:	ASTM E1886-19, ASTM E1996-20		
Product Rating:	Missile Level D, Wind Zone 3, DP+/-50, 120x63		
Rated Dimensions:	Max Width:	120 in	Max Height: 63 in
Linked Structural CARs:	875-181		

Qualifying Test information:

Test Report No:	2836T0011
Test Report Expiration:	4/29/2030

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com



Authorized By:

Shaun Shaull
Shaun Shaull 2026.05.07
07:28:02 -04'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Impact Performance Certification Authorization Report

Revision History

Rev #	Date	Description
0	5/7/2026	Initial issuance.