

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016994
DATE: 05/26/2026
CERTIFICATION PROGRAM: Structural
COMPANY: Robinson
CODE: 3167-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Robinson Windows, LLC 13780 Benchmark Drive Farmers Branch, Texas 75234	Series "100" Vinyl Fixed Window Configuration: O Glazing: IG-Ext. 1/8" Annealed Glass/Int. 3/32" Annealed Glass/0.090" Saflex PVB Interlayer/3/32" Annealed Glass Frame: W-1207mm(47.50") H-1816mm(71.50") DLO: W-1137mm(44.75") H-1746mm(68.75")

SPECIFICATION	PRODUCT RATING
ASTM E1886-19 ASTM E1996-23	Design Pressure: ± 2400 Pa (± 50 psf) Missile Level D Large Missile Impact Rated

Product Tested By: Construction Consulting Laboratory
Report No: CCL 26-098
Expiration Date: May 31, 2030

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com

NOPC-03/30/2023