

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016987
DATE: 05/12/2026
CERTIFICATION PROGRAM: Structural
COMPANY: Robinson
CODE: 3167-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Robinson Windows, LLC 13780 Benchmark Drive Farmers Branch, Texas 75234	Series "100" Vinyl Side Load Single Hung Window (w/Sill Extender) Configuration: O/X Glazing: Insulating Glass (Annealed) Frame: W-1207mm(47.52") H-2121mm(83.50") Sash: W-1156mm(45.51") H-1060mm(41.73") DLO: W-1073mm(42.25") H-978mm(38.50")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22	Class LC-PG60 1207 x 2121 (48 x 84)-H Design Pressure: ± 2880 Pa (± 60 psf) Water Penetration Resistance Test: 440 Pa (9.19 psf)

Product Tested By: Construction Consulting Laboratory
Report No: CCL 26-052
Expiration Date: January 31, 2030

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shirley".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023