NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI016865.01**
DATE:	**12/16/2025**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Robinson**
CODE:	**3167-1**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Robinson Windows, LLC **13780 Benchmark Drive** **Farmers Branch, Texas 75234**	**Series "Kodiak 100"** **Vinyl Horizontal Sliding Window** **(w/o Sill Extender)** Configuration: XO Glazing: Insulating Glass (Annealed) Frame: W-1816mm(71.50") H-1207mm(47.52") Sash: W-908mm(35.75") H-1156mm(45.51") DLO: W-826mm(32.52") H-1073mm(42.24")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/1.S.2/A440-22	**Class LC-PG40 1816 x 1207* (72 x 48*)-HS** **Design Pressure: 1920 Pa (40 psf)** **Positive Design Pressure: 2640 Pa (55 psf)** **Negative Design Pressure: 2640 Pa (55 psf)** **Water Penetration Resistance Test: 290 Pa (6.06 psf)**

Product Tested By: Construction Consulting Laboratory
Report No: CCL 25-277
Expiration Date: **November 30, 2029**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com