Impact Performance
Certification Authorization Report

MIDCO Building Products

1040 Dick Castleman Bypass
Mayfield, KY 42066, USA

Certification ID:	1736-107
Company Code:	1736
Certification Date:	5/20/2026
Revision No:	1
Revision Date:	6/10/2026
Expiration Date:	4/30/2030

Product Rating Information:

Model:	Fiberglass Glazed Outswing Hinged Door			
Operator Type:	SHD			
Configuration:	No, GS - 5/16" Ann Lami IG			
Referenced Standard:	ASTM E1886-19, ASTM E1996-23			
Product Rating:	Missile Level D, Wind Zone 4, DP+/-60, ~38x81			
Rated Dimensions:	**Max Width:**	38 in	**Max Height:**	81 in
Linked Structural CARs:	1736-104			

Qualifying Test information:

Test Report No:	MED-2239bR2
Test Report Expiration:	4/30/2030

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Fenestration Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com

ANSI National Accreditation Board ACCREDITED ISO/IEC 17065 PRODUCT CERTIFICATION BODY

Authorized By: Shaun Shaull 2026.06.10 07:45:59 -04'00'

Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500

Revision History

Rev #	Date	Description
0	5/20/2026	Initial issuance.
1	6/10/2026	Updated company name.