NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI017017**
DATE:	**06/18/2026**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Regency**
CODE:	**750-1**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Regency Plus, Inc. **2000 Locust Gap Highway** **Mount Carmel, PA 17851**	**Series "1320"** **Vinyl Casement Window** Configuration: XOX Glazing: Insulating Glass (Annealed) Frame: W-2819mm(111") H-1600mm(63") Vent: W-673mm(26.50") H-1556mm(61.25") DLO: W-540mm(21.25") H-1432mm(56.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 **AAMA/WDMA/CSA 101/I.S.2/A440-17**	**Class LC-PG50 2819 x 1600 (111 x 63)-C** **Design Pressure: ±2400 Pa (±50 psf)** **Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)**

Product Tested By: Molimo, LLC
Report No: 33056.01-106-11
Expiration Date: **June 30, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com