

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016829.04
DATE: 05/26/2026
CERTIFICATION PROGRAM: Structural
COMPANY: Robinson
CODE: 3167-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Robinson Windows, LLC 13780 Benchmark Drive Farmers Branch, Texas 75234	Series "Kodiak 200" Vinyl Twin Single Hung Windows w/Transom Configuration: O/O/XO/X Glazing: Insulating Glass (Annealed) Frame: W-1816mm(71.59") H-2425mm(95.47") Sash: W-845mm(33.27") H-738mm(29.06") DLO: W-1705mm(67.13") H-787mm(30.98")

SPECIFICATION	PRODUCT RATING
AAMA 450-20 AAMA/WDMA/CSA 101/1.S.2/A440-22	Class R-PG50 1829 x 2425 (72 x 96)-H Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test: 360 Pa (7.52 psf)

Product Tested By: Construction Consulting Laboratory
Report No: CCL 25-232/CCL 25-227/CCL 25-214
Expiration Date: September 30, 2029

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi".

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023