AAMA CERTIFICATION PROGRAM

An FGIA Product Certification Program

AUTHORIZATION FOR PRODUCT CERTIFICATION

Vytex Windows
9425 Washington Blvd. N.
Laurel, MD 20723

This authorization is based on the successful completion of tests and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED		
AAMA/WDMA/CSA 101/I.S.2/A440-22 LC-PG55-2134x1524 (84x60)-FW	**TAS 201, 202, 203**			
COMPANY AND CODE	Missile Level: **Large** Rating: **+55/-55, 84x60**	**CPD NO.**	**SERIES MODEL & PRODUCT DESCRIPTION**	**MAXIMUM SIZE TESTED**
Vytex Windows Code: VYW	Rating above conforms to requirements of: **TAS 201, TAS 202, and TAS 203**	**23183**	**3300 NARROW PW (PVC)(O)(IG) (INS TEMP/0.090" SGP LAM GL)(ASTM)**	**FRAME 2134 mm x 1524 mm (84" x 60")**

This Certification will expire **January 20, 2030** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

Molimo, LLC

Report No: **30144.01-106-11**

Date of Report: **February 11, 2025**
Date Test Completed: **January 20, 2025**

Missile Impact Test & Report By:

Molimo, LLC

Report No: **33106.01-106-13-R1**

Date of Report: **June 5, 2026 (Revised July 31, 2026)**
Date Test Completed: **May 11, 2026**

Evaluated for Certification: **August 20, 2026**

Associated Laboratories, Inc.

Authorized for Certification: **August 20, 2026**

Fenestration and Glazing Industry Alliance
1900 East Golf Road Schaumburg, IL 60173

(Validator / Operations Administrator)

ACP-14 (Rev. 5/24)