NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI017093**
DATE:	**09/08/2026**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Quaker**
CODE:	**031-1**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Quaker Window Products **504 Highway 63 South** **Freeburg, MO 65035**	**Series "C200"** **Aluminum Outswing Side Hinged Door** Configuration: X Glazing: IG-Ext. 1/4" Tempered Glass/Int.-1/4" Heat Strengthened Glass/ 0.090" SentryGlas Cardinal Interlayer/1/4" Heat Strengthened Glass Frame: W-1067mm(42") H-3048mm(120") Panel: W-1006mm(39.63") H-2981mm(117.38") DLO: W-829mm(32.63") H-2813mm(110.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 **ASTM E1886-19** **ASTM E1996-20**	**Class R/LC-PG50 1067 x 3048 (42 x 120)-SHD** **Design Pressure: ±2400 Pa (±50 psf)** **Water Penetration Resistance Test Pressure: 360 Pa (7.50 psf)** **Canadian Infiltration/Exfiltration Level: A3** **Missile Level D - Wind Zone 3**

Product Tested By: Intertek, LLC
Report No: T4352.02-801-47/S2558.01-801-44
Expiration Date: **January 31, 2030**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com