

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI017095.01
DATE: 09/08/2026
CERTIFICATION PROGRAM: Structural
COMPANY: Quaker
CODE: 031-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Quaker Window Products 504 Highway 63 South Freeburg, MO 65035	Series "W200" Aluminum Outswing Side Hinged Door Configuration: X Glazing: IG-Ext. 1/4" Tempered Glass/Int.-1/4" Heat Strengthened Glass/ 0.090" SentryGlas Cardinal Interlayer/1/4" Heat Strengthened Glass Frame: W-1067mm(42") H-3048mm(120") Panel: W-1006mm(39.63") H-2981mm(117.38") DLO: W-829mm(32.63") H-2813mm(110.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 ASTM E1886-19 ASTM E1996-20	Class R/LC-PG50 1067 x 3048 (42 x 120)-SHD Design Pressure: ± 2400 Pa (± 50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.50 psf) Canadian Infiltration/Exfiltration Level: A3 Missile Level D - Wind Zone 3

Product Tested By: Intertek, LLC
Report No: T8537.04-801-47/S2558.01-801-44
Expiration Date: May 31, 2030

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023