

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI017096
DATE: 09/08/2026
CERTIFICATION PROGRAM: Structural
COMPANY: Quaker
CODE: 031-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Quaker Window Products 504 Highway 63 South Freeburg, MO 65035	Series "W/C200" Aluminum Outswing French Door Configuration: XX Glazing: IG-Ext. 1/4" Tempered Glass/Int.-1/4" Heat Strengthened Glass/ 0.090" SentryGlas Cardinal Interlayer/1/4" Heat Strengthened Glass Frame: W-2134mm(84") H-3048mm(120") Panel: W-1033mm(40.69") H-2981mm(117.38") DLO: W-856mm(33.69") H-2804mm(110.38")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 ASTM E1886-19 ASTM E1996-20	Class R/LC-PG50 2134 x 3048 (84 x 120)-SHD Design Pressure: ± 2400 Pa (± 50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.50 psf) Canadian Infiltration/Exfiltration Level: A3 Missile Level D - Wind Zone 3

Product Tested By: Intertek, LLC
Report No: T8537.02-801-47/S2558.01-801-44
Expiration Date: May 31, 2030

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023