

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI016777.07-R2
DATE: 06/24/2026
CERTIFICATION PROGRAM: Structural
COMPANY: Quaker
CODE: 031-1
REVISION DATE: 08/05/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Quaker Window Products 504 Highway 63 South Freeburg, MO 65035	Series "C200/W200" Aluminum Multi Sliding Glass Door Configuration: OXXO Glazing: IG-Ext. 1/4" Tempered Glass/Int. 1/4" Heat Strengthened Glass/0.090" PVB Cardinal Interlayer/1/4" Heat Strengthened Glass OR IG-Ext. 1/4" Tempered Glass/Int. 1/4" Heat Strengthened Glass/0.090" SG Cardinal Interlayer/1/4" Heat Strengthened Glass Frame: W-4877mm(192") H-3048mm(120") Panel: W-1248mm(49.13") H-2958mm(116.44") DLO: W-1068mm(42.06") H-2780mm(109.44")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-22 ASTM E1886-19 ASTM E1996-20	Class R-PG50 4877 x 3048 (192 x 120)-SD Class LC-PG50 4877 x 3048 (192 x 120)-SD Design Pressure: ±2400 Pa (±50 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.50 psf) Canadian Air Infiltration/Exfiltration Level: A3 Missile Level D - Wind Zone 3

Product Tested By: Intertek, PLC
Report No: T4352.03-801-47
Expiration Date: January 31, 2030

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124/Email: nami@namiinc.com

NOPC-03/30/2023