



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program

AUTHORIZATION FOR PRODUCT CERTIFICATION

Vytex Windows
9425 Washington Blvd. N.
Laurel, MD 20723

This authorization is based on the successful completion of tests and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-22 LC-PG55-2794x1600 (110x63)-HS	TAS 201, 202, 203				
COMPANY AND CODE	Missile Level: Large Rating: +55/-55, 110x63	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
Vytex Windows Code: VYW	Rating above conforms to requirements of: TAS 201, TAS 202, and TAS 203	23186	6200i IMPACT HORIZONTAL SLIDER (PVC)(XOX)(OG) (INS 0.090" SGP LAM GL) (MODIF)(REINF)(ASTM)	FRAME (mm) 2794 x 1600 (110" x 63")	SASH (mm) 914 x 1480 (36" x 58")

This Certification will expire **January 23, 2030** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

Molimo, LLC

Report No: **30147.01-106-11-R1**

Date of Report: **February 11, 2025 (Revised March 14, 2025)**

Date Test Completed: **January 24, 2025**

Missile Impact Test & Report By:


Molimo, LLC

Report No: **31838.01-106-11-R1**

Date of Report: **June 5, 2026 (Revised July 31, 2026)**

Date Test Completed: **February 19, 2026**

Evaluated for Certification: **August 18, 2026**


Associated Laboratories, Inc.

Authorized for Certification: **August 18, 2026**


Fenestration and Glazing Industry Alliance
1900 East Golf Road Schaumburg, IL 60173



(Validator / Operations Administrator)