AAMA CERTIFICATION PROGRAM

An FGIA Product Certification Program

AUTHORIZATION FOR PRODUCT CERTIFICATION

Simonton Windows
1 Cochrane Dr.
Pennsboro, WV 26415

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATION	RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-11 R-PG50*-1854x1880 (73x74)-H				
COMPANY AND CODE	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
Simonton Windows Code: SIM	10599	41-18 TWIN SH (PVC)(O/X.O/X)(IG & OG) (INS GL)(MODIF)(REINF) (TILT)(ASTM)	FRAME 1854 mm x 1880 mm (73" x 74")	SASH 864 mm x 911 mm (34" x 36")

This Certification will expire **March 11, 2032 (extended from March 11, 2027)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Product Tested and Reported by: **Architectural Testing, Inc.**

Report No.: **C6560.01-109-47**

Date of Report: **April 2, 2013**
Date Test Completed: **March 11, 2013**

Evaluated for Certification: **June 19, 2026**

Associated Laboratories, Inc.

Authorized for Certification: **June 19, 2026**

Fenestration and Glazing Industry Alliance
1900 East Golf Road Schaumburg, IL 60173

(Validator / Operations Administrator)

ACP-04 (Rev. 5/24)