



Simonton Windows
1 Cochrane Dr.
Pennsboro, WV 26415

Attn: Tina Seese

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-08 R-PG50*-965x1829 (38x72)-H	AAMA 506-06				
COMPANY AND CODE	Missile Level: C Rating: +50/-50, 38x72 Wind Zone: 2	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
Simonton Windows Code: SIM		8881	42-19 DH (PVC)(X/X)(OG) (INS 0.060" LAM GL) (MODIF)(REINF)(TILT) (ASTM)	<u>FRAME (mm)</u> 965 x 1829 (3'2" x 6'0")	<u>SASH (mm)</u> 911 x 913 (3'0" x 3'0")

This Certification will expire **September 14, 2024 (extended from September 14, 2019 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

Architectural Testing, Inc.

Report No: **B7589.01-501-47; ref. A3993.01-501-47**

Date of Report: **March 21, 2012; October 7, 2010**


Missile Impact Test & Report By:

Architectural Testing, Inc.

Report No: **B9722.01-109-47**

Date of Report: **June 8, 2012**

Evaluated for Certification: **May 16, 2019**


Associated Laboratories, Inc.

Authorized for Certification: **May 16, 2019**



American Architectural Manufacturers Association