



**AAMA CERTIFICATION PROGRAM**  
An FGIA Product Certification Program

**AUTHORIZATION FOR PRODUCT CERTIFICATION**

**Simonton Windows**  
1 Cochrane Dr.  
Pennsboro, WV 26415

This authorization is based on the successful completion of tests and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11 R-PG50*-914x1880 (36x74)-H</b>	<b>AAMA 506</b>				
COMPANY AND CODE	Missile Level: <b>C</b> Rating: <b>+50/-50, 36x74</b> Wind Zone: <b>2</b>  Rating above conforms to requirements of: <b>ASTM E1886</b> and <b>E1996</b>	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
<b>Simonton Windows Code: SIM</b>		<b>8355</b>	<b>42-19 DH (PVC)(X/X)(OG) (INS 0.060" LAM GL) (MODIF)(REINF)(TILT) (ASTM)</b>	<u>FRAME (mm)</u> <b>914 x 1880 (36" x 74")</b>	<u>VENT (mm)</u> <b>860 x 940 (34" x 37")</b>

This Certification will expire **September 14, 2029 (extended from September 14, 2024 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Structural Test & Report By:

**Architectural Testing, Inc.**

Report No.: **B7589.01-501-47; ref. A3993.01-501-47**

Date of Reports: **March 21, 2012; October 7, 2010**

Date Tests Completed: **March 5, 2012; September 14, 2010**

Missile Impact Test & Report By:


**Architectural Testing, Inc.**

Report No: **B7583-501-47**


Date of Report: **March 21, 2012 (Revised June 11, 2012)**

Date Test Completed: **March 6, 2012**

Evaluated for Certification: **June 14, 2024**

  
Associated Laboratories, Inc.

Authorized for Certification: **June 14, 2024**



Fenestration and Glazing Industry Alliance  
1900 East Golf Road Schaumburg, IL 60173



(Validator / Operations Administrator)

ACP-14 (Rev. 5/24)