

NOTICE OF PRODUCT CERTIFICATION



Company: Masonite International Corporation
1955 Powis Road
West Chicago, IL 60185

Product: Fiberglass Glazed Inswing or Outswing Door
(w/Wood Frame unless noted)
Specification: TAS 202-94

Certification No.: NI006220.01-R2
Certification Date: 09/23/2005
Expiration Date: 12/31/2026
Revision Date: 11/14/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Structural Design Pressure	Water Test Pressure	Missile Impact Rated	Test Report Number Drawing Number & Comments
XX Double	I/S	Glazed	6'0" x 6'8"	+50.5/-50.5	2.86 psf	No	CTLA-805W-2 Maximum Panel Size: 3'0" x 6'8" Anchor Detail-MA-FL0143-05
XX Double	O/S	Glazed	6'0" x 6'8"	+50.5/-50.5	7.60 psf	No	CTLA-805W-2 Maximum Panel Size: 3'0" x 6'8" Anchor Detail-MA-FL0143-05

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072
Tel: (804) 684-5124/nami@namiinc.com

NAMI AUTHORIZED SIGNATURE: _____