



LISTING INFORMATION OF Clopay WINDCODE® W4 Commercial Doors

SPEC ID: 27304

Clopay Building Products Co., Inc. (CBPC)
8585 Duke Blvd.
Mason, OH 45040

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

WIND LOAD RESISTANT DOORS**Clopay WINDCODE® W4 Commercial Doors**

Clopay WINDCODE® W4 Commercial Sectional Doors				
	Impact Rating	Max. Width	Design Pressure Pos.	Design Pressure Neg.
01 Single Car Double Skin Insulated	N/A	9'-0"	+28 PSF	-29 PSF
02 Double Car Double Skin Insulated	N/A	16'-0"	+25.5 PSF	-25.5 PSF
03 Single Car Steel Pan	N/A	9'-0"	+25 PSF	-32 PSF
04 Double Car Steel Pan	N/A	16'-0"	+24 PSF	-24.5 PSF
05 Sectional Single Car 10'-2" Double Skin Insulated	N/A	10'-2"	+25 PSF	-28 PSF
06 Sectional Double Car 20'-2" Double Skin Insulated	N/A	20'-2"	+25 PSF	-28 PSF
07 Sectional Double Car 24'-2" Double Skin Insulated	N/A	24'-2"	+25 PSF	-25 PSF
08 Sectional Single Car 10'-2" Double Skin Insulated	N/A	10'-2"	+25 PSF	-25 PSF
09 Ribbed Steel 12'-2"	N/A	12'-2"	+25 PSF	-25 PSF
10 Ribbed Steel 16'-2"	N/A	16'-2"	+25 PSF	-25 PSF
11 Ribbed Steel 20'-2"	N/A	20'-2"	+25 PSF	-25 PSF
12 Ribbed Steel 24'-2"	N/A	24'-2"	+25 PSF	-25 PSF
13 Service Station Door	N/A	24'-2"	+25 PSF	-25 PSF

Attribute

CSI Code

Listed or Inspected

Report Number

Criteria

Value

08 30 00 Specialty Doors and Frames

LISTED

100487442MID-002-R1

ASTM E330 (2002)

Static Load Test - Design Pressure	See Table
Intertek Services	Certification
Listing Section	WIND LOAD RESISTANT DOORS
Test Original Issue Date	2012-01-26