

AAMA CERTIFICATION PROGRAM



AUTHORIZATION FOR PRODUCT CERTIFICATION

Simonton Windows
1 Cochrane Dr.
Pennsboro, WV 26415

Attn: Tina Seese

The product described below is hereby approved for listing in the next issue of the AAMA Certified Products Directory. The approval is based successful completion of tests, and the reporting to the Administrator of the results of tests, accompanied by related drawings, by an AAMA Accredited Laboratory.

1. The listing below will be added to the next published AAMA Certified Products Directory.

SPECIFICATIONS		RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-08 R-PG50-2724x2419 (107x95)-SD	AAMA 506				
COMPANY AND CODE	Missile Level: D Rating: +50/-50, 107x95 Wind Zone: 4	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
Simonton Windows Code: SIM	Rating above conforms to the requirements of: ASTM E1886 and E1996	2534	11-11 SGD (PVC)(OXO)(OG) (INS TEMP/PVB LAM GL) (MODIF)(REINF)(ASTM)	FRAME (mm) 2724 x 2419 (8'11" x 7'11")	PANEL (mm) 916 x 2346 (3'0" x 7'8")

2. This Certification will expire **July 25, 2021 (extended from July 25, 2016 per AAMA 103-15)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

3. Structural Test & Report By:

Element Materials Technology

Report No: **ESP010622P-5**

Date of Report: **August 10, 2012**


Missile Impact Test & Report By:

Element Materials Technology

Report No: **ESP010622P-6**

Date of Report: **August 10, 2012**

Validated for Certification


 Associated Laboratories, Inc.

Authorized for Certification


 American Architectural Manufacturers Association

Date: **March 28, 2016**

Cc: AAMA

JGS

ACP-14 (Rev. 1/11)