

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006541.03-R10
DATE: 07/26/2012
CERTIFICATION PROGRAM: Structural
COMPANY: YKK AP America
CODE: 860-1
REVISION DATE: 06/26/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
YKK AP America, Inc. 101 Marietta Street NW, Suite 2100 Atlanta, GA 30303	StyleGuard (NonImpact) Double Hung Vinyl Window Configuration: X/X Glazing: Insulating Glass (Annealed) Frame: W-1321mm(52") H-1575mm(62") Sash: W-1245mm(49") H-781mm(30.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG50 1321 x 1575 (52 x 62)-H Design Pressure: ±2400 Pa (50 psf)

Product Tested By: Hurricane Test Laboratory, LLC
Report No: G231-0110-08 Spec. 4/0231-1107-05/W-1954/W-2086
Expiration Date: **December 31, 2030**

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com

NOPC-03/30/2023