

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI009357.06-R10  
**DATE:** 02/15/2008  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** YKK AP America  
**CODE:** 860-1  
**REVISION DATE:** 06/16/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS                                                                             | PRODUCT DESCRIPTION                                                                                                                                                                                        |
|------------------------------------------------------------------------------------------------------|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>YKK AP America, Inc.</b><br><b>101 Marietta Street NW, Suite 2100</b><br><b>Atlanta, GA 30303</b> | <b>StyleView®</b><br><b>Double Hung Vinyl Window</b><br>Configuration: X/X<br>Glazing: Insulating Glass (Annealed)<br><br>Frame: W-1207mm(47.5") H-1257mm(49.5")<br>Sash: W-1136mm(44.72") H-626mm(24.66") |

| SPECIFICATION                                                                    | PRODUCT RATING                                                                                                                                                                                   |
|----------------------------------------------------------------------------------|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b><br><b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b> | <b>Class R-PG50 1207 x 1257 (48 x 50)-H</b><br><b>H-R50 1207 x 1257 (48 x 50)</b><br><b>Design Pressure: ±2395 Pa (±50 psf)</b><br>Water Penetration Resistance Test Pressure: 360 Pa (7.50 psf) |

Product Tested By: Hurricane Test Laboratory, LLC  
Report No: G231-0803-07-Unit 6/W-1648/W-2075/W-2119/W-2128/W-2179/W-2190/W-2194  
Expiration Date: **December 31, 2030**

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be "Shi D".

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
[nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023