

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009357-R10
DATE: 02/15/2008
CERTIFICATION PROGRAM: Structural
COMPANY: YKK AP America
CODE: 860-1
REVISION DATE: 06/16/2026

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
YKK AP America 101 Marietta Street NW, Suite 2100 Atlanta, GA 30303	StyleView® Double Hung Window Configuration: X/X Glazing: Insulating Glass (Annealed) Frame: W-1207mm(47.5") H-1816mm(71.5") Sash: W-1136mm(44.72") H-906mm(35.66")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17	Class R-PG35 1207 x 1816 (48 x 72)-H

Product Tested By: Hurricane Test Laboratory, LLC
Report No: G231-0803-07 Unit 7/W-1954/W-2119/W-2128/W-2179/W-2190/W-2194
Expiration Date: **December 31, 2030**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "Shi D", is written over a horizontal line.

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023